



SAFETY ALERT – OSHA RECORDABLE SIF/SIR CALLAWAY ENERGY CENTER

Date and Time of Incident: May 14, 2021 @ 1300

Incident Location: Iso-phase (Main Transformers)

Condition Report No.: 202102792

Job at Hand: Accessing Scaffold

The Incident: A supplemental co-worker was ascending scaffold while supporting the Isophase work. While nearing the lower platform they lost their grip/footing and fell backward approximately 26 feet to the ground. The MERT was activated and the co-worker transported offsite by ambulance.

Immediate Actions:

- Prompt notification and activation of MERT.
- Stopped work and a standdown held with other plant projects.

Possible Incident Cause:

- Body Mechanics (Focus 5) – Ensure positive contact with rungs is maintained.
- New to the work role.

Take Aways from Incident :

- Stop when unsure, use a questioning attitude with new job tasks.
- Consider your task at hand and ensure you are prepared to perform the work in the safest way possible. Eliminate the Risk or apply a mitigating strategy to minimize the risk.



Refer any questions to Chris Pfau, Safety Supervisor, Callaway Energy Center 314-285-8651