01

01 00 00 01

Sheet 1 of 1

TABLE OF CONTENTS

GENERAL INFORMATION

GENERAL G-TECH MAP SYMBOLS

01-00-01-01

01-00-01-02

1. Purpose of Construction Standards

The Standards in this book have been prepared for the use of Ameren Corporation personnel concerned with the construction, operation and maintenance of the Company's electric distribution facilities. An understanding of the necessity for these system–wide construction standards is of the greatest importance to the continued expansion of Ameren's facilities.

Standards properly developed and applied accomplish the following objectives.

- a. Establish desired design criteria and performane levels.
- b. Insure uniform, safe and economical construction practices.
- c. Provide information on materials and their proper application.
- d. Minimize engineering and estimating time.
- e. Provide the basis for automated material and labor determination for work request and work order purposes.

2. Scope and Application

Ameren Corporation Standards cover the type of construction and the materials that shall be used for 4kV to 14.4kV distribution systems, outdoor lighting systems, and for 34kV and 69kV subtransmission systems.

The following guidelines shall be followed in applying these Standards.

- a. All new construction shall conform to these standards.
- b. When existing poles are replaced, all construction on the new poles shall conform to these standards.
- c. When additional circuits are installed, or circuits are replaced on existing poles, the arrangement shall conform to the standards as nearly as is reasonable and practical.
- d. Existing lines shall not be rebuilt for the sole purpose of conforming to these standards.

3. Conformance to National, State and Local Codes

Every effort has been made in the development of the Ameren Construction Standards to give proper recognition of and insure conformance to published codes of governmental bodies. All construction covered by the standards in this book meet the minimum requirements of the current edition of the National Electrical Safety Code.

4. Responsibility for Interpretation

Questions concerning the interpretation of these standards shall be directed to the Supervising Engineer in the Distribution Standards Group.

5. Standards Organization - Unitized Assemblies

This standards book is made up of various major sections, some providing basic units of assembly such as insulators, crossarms, guys, etc. Many of these basic units are then further employed as sub–assemblies in other sections, such as the configuration and switch sections of the book. However, there is a practical limit to the number of various combinations of these units for which standard drawings can be developed. As a result, several different standards are required to completely specify the construction for each pole.


Computerized Material and Labor Take-Off

Provisions have been incorporated into these standards which, when properly applied, will develop the associated materials, installation labor manhours and total costs by computer. This system of computerized materials take-off is now part of the DOJM system. In DOJM terminology, the Construction Standard bill-of-material is called a macro or supermacro. A major stock number or a labor code is called a comptabile unit. Minor stock number for any particular macro are gathered together to form one compatible unit for all minor items on that Construction Standard. Some of the general provisions of the computerized material and labor take-off system are described in the following paragraphs.

DISTRIBUTION CONSTRUCTION STANDARDS



ENG: JLH REV. NO: 4



To provide for computerized material take–off, an eight digit standards numbering system has been developed. A separate number is assigned to each variation of construction and a complete bill of material is listed on the standard for each of the variations covered. This same number with an appropriate bill of materials and associated non–material operations, if any, are recorded on the computer. Specifying the proper eight–digit standard number will, in many instances, be all that is required to obtain the proper materials, labor and costs associated with the installation or removal of the standard. In other cases, one or more adders indicated in the Bill of Materials of the standard will have to be added separately.

b. Adder Items "@"

Where it is not practical to give all the variations of an assembly of different unit standards on one standard sheet, a reminder is given in the Bill of Materials that additional materials are required. This reminder is in the form of an "@" prefixing the standard number, stock number, or wire size specific item which must be specified separately.

c. Wire Size Variable "W"

In cases where the material required on a standard varies with the wire size, a system has been designed to indicate adders to be included with a wire size suffix. See Sheet 3 of this standard for appropriate wire size suffixes. This suffix will automatically provide the proper materials when an adder is called for. The computer selects from a wire size table such items as connectors, deadends, jumper and lead wire, ties, etc. If the adder is not suffixed with an acceptable wire size, DOJM will not allow the DOJM code to be entered.

d. Transformer Standards

Transformers are specified on work requests by their stock number. Materials which vary with the transformer size and type will be automatically specified along with the transformer by the computer. These items, such as leads, connectors and bolts, are indicated by the letter "T" on the transformer standard bill of materials. Other items must be specified by listing the Standard Number for mounting the transformer.

e. Additions and Deletions

Materials may be added to or deleted from a standad by listing them on the line construction work request (NTRY Screen). This may be done either by unit standard numbers or by stock numbers. This will be useful in cases such as where a different crossarm size is required, where wire sizes are different, where some items are already installed, etc.

ENG: JLH REV. NO: 4

ACCEPTABLE WIRE SIZE SUFFIXES

<u>NEUTRAL</u>			2.4kV through 69kV				
,	WIRE	SIZE	SUFFIX	WIRE	SIZE		SUFFIX
#6	CU	Bare	6C	#4	ACSR	Bare	4A
#4	CU	Bare	4C	#2	ACSR	Bare	2A
#2	CU	Bare	2C	#1/O	AAAC	Bare	10A
#1/0	CU	Bare	10C	#3/0	ACSR	Bare	30A
#4	ACSR	Bare	4A	#4/0	ACSR	Bare	40A
#1/0	AAAC	Bare	10A	335.6	T-2ACSR	Bare	335T2
				336.4	ACSR	Bare	336A
				477	ACSR	Bare	477A
120/2	240 VOLTS O	PEN WIDE	<u>SECONDARY</u>	556.5	AA	Bare	556A
,	WIRE	SIZE	SUFFIX	795	AA	Bare	795A
2-#6	CU	WP	6W	954	AA	Bare	954A
1-#6	CU	Bare					
				#4	ACSR	Poly	4P
2-4#	CU	WP	4W	#2	ACSR	Poly	2P
1-#6	CU	Bare		#1/0	AAAC	Poly	10P
				336.4	AA	Poly	336P
2-#2	CU	WP	2W	556.5	AA	Poly	556P
1-#4	CU	Bare					
				#4	ACSR	TreeWire	4T
2-#4/0	AA	Poly	40P	#2	ACSR	TreeWire	2T
1-#1/0	AAAC	Bare		#1/0	AAAC	TreeWire	10T
				336.4	ACSR	TreeWire	336T
				556.5	AA	TreeWire	556T
				#6	CU	Bare	6C
STATIC WIRE		<u>.</u>	SUFFIX	#4	CU	Bare	4C
3#7	AW	Bare	37AW	#2	CU	Bare	2C
110.8	ACSR	Bare	110A	#1/0	CU	Bare	10C
				#4/0	CU	Bare	40C
				350	CU	Bare	350C
COPPERWELD SUFFIX		SUFFIX	500	CU	Bare	500C	
#6A	CWC	Bare	6AC				
#4A	CWC	Bare	4AC				
#2A	CWC	Bare	2AC				

DISTRIBUTION CONSTRUCTION STANDARDS



ENG: JLH REV. NO: 4

2.4kV through 69kV

	WIRE	SIZE	(SUFFIX
#6	C	U	WP	6W
#4	C	U	WP	4W
#2	C	U	WP	2W
#1/	0 C	U	WP	10W
#4/	0 C	U	WP	40W
500) C	U	WP	500W

1. For wire sizes and voltages not shown, material must be specified separatelyl.



ENG: JLH REV. NO: 4

GENERAL G-Tech Map Symbols

Sheet	1	of	2	

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	OPEN SOLID BLADE SWITCH (MO)	B	OPEN BREAKER
\boxtimes	CLOSED SOLID BLADE SWITCh (MO)	В	CLOSED BREAKER
\bigcirc	OPEN SOLID BLADE SWITCH (IL)	R	OPEN RECLOSER
✓.	CLOSED SOLID BLADE SWITCH (IL)	R	CLOSED RECLOSER
\sim	CLOSED FUSED SWITCH	S	OPEN SECTIONALIZER
0	OPEN FUSED SWITCH	S	CLOSED SECTIONALIZER
П	OPEN SPLIT	®	REGULATOR
\bigcap	CLOSED SPLIT	\Diamond	GENERATOR
\triangle	OVERHEAD TRANSFORMER (1PH)	$\dashv C$	CAPACITOR
\triangle	OVERHEAD TRANSFORMER (3PH)	NP	NETWORK PROTECTOR
	PADMOUNT TRANFORMER (1PH)	K	KEY INTERLOCK
	PADMOUNT TRANFORMER (3PH)	0	OPEN LOAD BREAK ELBOW
\sim	SPACER CABLE	•	CLOSED LOAD BREAK ELBOW
0	OPEN CIRCUIT SWITCH PAD	S	RADIO CONTROL SYMBOL
	SWITCH PAD (MO)	} {	STEPDOWN TRANSFORMER
5 { 1 0	SWITCH PAD (IL)	\bigcirc	LIGHTING SUBSTATION
MH	MANHOLE	©	MAJOR CUSTOMER
HH	HANDHOLE	См	CUSTOMER SUBSTATION MANUAL
• •	JUNCTION BOx (4 WAY)	© A	CUSTOMER SUBSTATION AUTOMATIC
• •	JUNCTION BOx (2 WAY)	M	PRIMARY METER



GENERALG-Tech Map Symbols

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
+	FEEDER ORIGIN		SUBSTATION
	FAULT INDICATOR	I	DOWN GUY
>	CABLE TERMINATION	←→	SPAN GUY
•	COMPANY POLE	$\qquad \qquad \\ \\$	TRANSMISSION TOWER
•	FOREIGN POLE		TRANSMISSION TOWER (FOREIGN)
\bigcirc	NETWORK BUS POSITION	Е	DEADEND
	ENCLOSED ROOM	0	JUNCTION
\bigcirc	VAULT	_	CABLE SPLICE
\sim	REACTOR	•	WIRE/PHASE CHANGE
СТ	CT BANK	- ₩	MUNICIPAL STREETLIGHT
\sim	CT ATTACHMENT	\(\forall \)	OVERHEAD FED STREETLIGHT
}}	POTENTIAL TRANSFORMER	*	UNDERGROUND FED STREETLIGHT
∜ ————————————————————————————————————	COUPLING CAPACITOR	\{\}	SUBSTATION TRANSFORMER
\sim	REACTOR	0	METER ATTACHMENT
1-1-	HIGH SPEED GROUND SWITCH	0	RELAY ATTACHMENT
₩	WAVE TRAP	(A) /R	MISC EQUIPMENT (REPEATER)
∘∘ lı	LIGHTNING ARRESTER	(M)	MISC EQUIPMENT (MCC /CRM)
h	GROUND	①	AIRCRAFT WARNING MARKER
•	DISTRICT TIE		

