

2025 Q1 DCS Changes List

Standard	Revision Description
Section 03	
03 00 00 01	Update Table of Contents
03 25 01 **	New Standard
03 25 02 **	New Standard
03 25 06 **	New Standard
03 25 07 **	New Standard
03 25 09 **	New Standard
03 25 11 **	New Standard
03 25 14 **	New Standard
03 25 24 **	New Standard
Section 07	
07 00 01 01	Update Table of Contents
07 00 01 01	Added additional stock codes of reel lengths for 1/0 (7) AAAC in Table 1
	Removed T2 ampacities and moved to 07 00 01 05
	Added additional stock code of reel lengths for 954 (45/7) ACSR in Table 1
07 00 01 03	Added mechanical specs for non-standard conductors
07 00 01 05	Added clarification of the initial 4 numbers for compression sleeves stock numbers in the column header of Table 5
	Added construction note 3 to help direct T2 jumper selection process
	Updated T2-954 compression sleeve stock number
	Added allowable angle of trunnion and suspension clamps for T2 conductors in Table 6
	Added stringing block information for all 4 standard T2 conductors in Tables 8 and 9
	Added new construction Note 5 noting availability of full roller selection/installation guides for each Standard T2 conductor
	Add T2 ampacities from 07 00 01 01
07 00 07 03	Fixed incorrect information in Sagging Method regarding load cases for conductor blowout and clearances
	Added reference note to Section 29 00 17 02
	Fixed deadend tensions for 954 (45/7) ACSR
	Fixed deadend tensions for 1272 (45/7) ACSR
07 00 07 06	Updated RBS of OPGW 72ct
07 00 08 01	Adjusted wording in armor rod and line guard guidelines to clarify span length requirements
07 00 09 01	Updated stock number for 110.8 (12/7) ACSR automatic splice
	Updated stock numbers for 1272 (45/7) ACSR full tensions and jumper/loop compression sleeves
	Updated stock numbers for 954 (45/7) ACSR and 1272 (45/7) ACSR inline bolted deadends
	Removed inline bolted clamp stock numbers and moved to 07 00 20 00
07 00 11 00	Updated drawing details to show insulators with dashed lines to indicate these are not included with the stock number
	Added max tension working loads to bolted deadends
07 00 20 00	Removed T2 stock numbers and moved to DCS 07 00 01 05
	Removed 34 & 69kV condition
	Added construction note 1 to help selection process

2025 Q1 DCS Changes List

Standards	Revision Description
07 00 25 00	Changed wording from 'connectors' to 'Parallel Groove Clamps' in Table 2
	Fixed stock numbers for some PG clamps in Table 2 from a date format to the appropriate conductor range
	Fixed bordering and stock number alignment in Table 3
07 00 30 00	Changed '954 AA' to '954 AA/ACSR'
07 00 80 00	Updated stock numbers for #6 and #4 Cu Poly leads and lead material for 795 AA and 954 AA/ACSR
07 00 81 00	Updated lead size to #2 for all appropriate stock numbers